



ADDENDUM #4

Eddyville Riverport & Industrial Development Authority (ERIDA)
ERIDA – Dolphins Project
Eddyville, Kentucky

BFW Project # 25223

Date: July 20, 2026

Attention: Bidders of above referenced project

This document contains responses to remaining questions submitted to date and a special note regarding deadlines.

Special Note:

The deadline for receipt of any remaining questions is 3 PM CST, Wednesday, July 22, 2016.

The bid due date remains unchanged; bids are due on **August 4, 2026 @ 7:30 AM CST.**

Questions and Answers:

Q1: The plans call for a 50-ton capacity on the mooring rings/ u bolts. Can you confirm if this capacity is only for the U-bolts, only for the mooring rings, or both? If both, will a 50ksi steel be appropriate if we are unable to find steel with a 50-ton capacity for the U-bolts?

The 50-ton capacity is for both the U-bolts and mooring rings. Yes, 50ksi steel is acceptable.

Q2: Are we able to use a non-KY pre-approved contractor for the field QC inspections?

Field QC inspections do not require an approved KYTC contractor. Inspections, personnel and procedures must be performed in accordance with standards for which the scope is being inspected. For instance, welding inspections must be performed by an inspector certified with AWS and ASNT. Qualifications of inspectors must be submitted and approved prior to performing the work.

Attachment Summary

- There are no attachments for this addendum